

TEKNOS A/S
Industrivej 19
6580 Vamdrup
DENMARK

Eurofins Product Testing A/S
Smedeskovvej 38
8464 Galten
Denmark

CustomerSupport@eurofins.com
www.eurofins.com/VOC-testing

VOC EMISSION TEST REPORT

Indoor Air Comfort GOLD®

20 April 2021

1 Sample Information

Sample name	TEKNOSAFE FLAME PROTECT 2468-00
Batch no.	311920-201
Production date	16/02/2021
Product type	Paint
Sample reception	09/03/2021

2 Brief Evaluation of the Results

Regulation or protocol	Conclusion	Version of regulation or protocol
French VOC Regulation		Decree of March 2011 (DEVL1101903D) and Arrêté of April 2011 (DEVL1104875A) modified in February 2012 (DEVL1133129A)
French CMR components	Pass	Regulation of April and May 2009 (DEVP0908633A and DEVP0910046A)
Italian CAM Edilizia	Pass	Decree 11 October 2017 (GU n.259 del 6-11-2017)
ABG/AgBB	Pass	Ausschuss zur gesundheitlichen Bewertung von Bauprodukten (August 2018)
Belgian Regulation	Pass	Royal decree of May 2014 (C-2014/24239)
Indoor Air Comfort®	Fail	Indoor Air Comfort 7.0 of May 2020
Indoor Air Comfort GOLD®	Fail	Indoor Air Comfort GOLD 7.0 of May 2020

Full details based on the testing and direct comparison with limit values are available in the following pages
Regarding pass/fail decision rule please see appendix

§ Deviation from method. Please see deviation section



Pernille Krintel
Analytical Service Manager



Maria Pelle Madsen
Analytical Chemist